

# Rubber Voltage Gloves



## MADE IN USA RUBBER VOLTAGE GLOVES

**GC0\_\_11**

**GC0\_\_14**

Sizes: 08-12; Class 0, Type 1

Curved fit in fingers for ease of movement and added comfort

Electrically tested and stamped with the initial test date

Compliance: NFPA 70E, CSA Z462, OSHA 1910.269, ANSI/ASTM D120



## FR GLOVE LINER

**G16RG\_\_**

Sizes: RG-LG

Arc Rating: 12 cal/cm²

Fabric/Material: 6.5 oz. Westex® UltraSoft® rib knit

Made in the USA

Single layer hand & double layer cuff for flexibility and dexterity

Can be used as a liner or voltage gloves for added comfort & protection

Compliance: NFPA 70E, CSA Z462, ASTM F1506, OSHA 1910.269



## RUBBER VOLTAGE GLOVE KITS

**KITGC\_\_AG (WITH LINER GLOVE)**

**KITGC\_\_**

Colors: Black, Red & Yellow

Kit includes: rubber voltage gloves, leather glove protectors & glove bag

Rubber voltage gloves are electrically tested & stamped with the initial test date

Compliance: NFPA 70E, CSA Z462, ANSI/ASTM D120, OSHA 1910.269



## RUBBER VOLTAGE GLOVES

**GC\_\_**

Colors: Black, Red & Yellow

Newly electrically tested and stamped with the initial test date before shipment

Should be worn with leather glove protectors to increase lifespan

Compliance: NFPA 70E, CSA Z462, ANSI/ASTM D120

NSA offers three different levels of protection for our Enespro® Rubber Voltage Gloves:

Class 00 - Max Use Voltage 500V AC/750V DC  
Class 0 - Max Use Voltage 1000V AC/1500V DC  
Class 2 - Max Use Voltage 17000V AC/25500V

\*\*Rubber Voltage Glove  
\_\_ Denotes Size Of Glove  
~ Available In Premium Kit | -AG

### MADE IN THE USA VOLTAGE GLOVES

Class	Length**	Sizes	Black	Yellow	Red
0	11"	08-12	GC0B__-USA		
0	14"	08-12	GC0B__14		GC0R__14

### MADE IN THE USA VOLTAGE GLOVE KITS

Class	Length**	Sizes	Black	Yellow	Red
0	11"	08-12	KITGC0B__-USA		
0	14"	08-12	KITGC0B__14		KITGC0R__14

### RUBBER VOLTAGE GLOVES

Class	Length**	Sizes	Black	Yellow	Red
00	11"	08-12	GC00B__	GC00Y__	GC00R__
0	11"	08-12	GC0B__	GC0Y__	GC0R__
2	14"	08-12	GC2B__	GC2Y__	GC2R__

### RUBBER VOLTAGE GLOVE KITS

Class	Length**	Sizes	Black~	Yellow~	Red~
00	11"	08-12	KITGC00B__	KITGC00Y__	KITGC00R__
0	11"	08-12	KITGC0B__	KITGC0Y__	KITGC0R__
2	14"	08-12	KITGC2B__	KITGC2Y__	KITGC2R__

# Rubber Voltage Gloves


## IMPORTANT INFORMATION TESTING AND RETESTING

- Gloves must be put into use within one year of test date
- If one year has passed since the gloves have been tested and they have not been opened, they must be sent back for retesting
- Once gloves are issued for use, they must be retested within 6 months from the date they were distributed to employees
- For additional information, refer to ASTM F496

Exact Test  
Date



Use your phone QR Reader app to scan  
your gloves' data matrix code



After you scan the data matrix code you will receive  
quick & easy access to your gloves' test report

## SIZING & STORAGE FOR ENESPRO<sup>®</sup> RUBBER VOLTAGE GLOVES

### Selecting the Correct Size

National Safety Apparel<sup>®</sup> offers our Enespro<sup>®</sup> Rubber Voltage Gloves in sizes ranging from 8 to 12. To make sure you are ordering the correct glove size, measure the circumference around your palm (see illustration). If you are in between sizes, we recommend ordering the larger size.

### The Correct Way to Store Your Gloves

To ensure gloves are safely stored:

- Keep out of high heat areas
- Avoid high moisture areas
- Don't place in direct sunlight
- Keep out of contact with any chemical substance
- Store flat & don't fold the gloves

